



**GUJARAT GAS COMPANY LIMITED**

GAS Division : Post Box No. 915, P. O. Navyug College,  
Adajan Gam, Surat - 395 009. Gujarat, India.  
Phone : 686373, 686328. Fax : 91-261-686362

Ref: GGCL/VD/210/97-98  
17 October, 1997

Kitec Industries (India) Limited  
C-18/11, Jeevan Bima Nagar, Borivili (W),  
Mumbai-400 103

Fax ; 022-8942549

Kind Attn. : Mr. Avinash Laddha, Managing Director  
Subject : Performance of Kitec Composite Pipes

Dear Sir,

This has reference to our telecon few days back regarding feedback on trial installations of imported 'Kitec' Composite pipe & brass forged fittings. We had installed the pipe in 4 domestic connections, approx. 2 years back. We have not received any complaints or faced any problem with any of the connection. In one connection, leakage developed from one joint, immediately after installations because of slight shortness in length of pipe, which was duly rectified.

We hope the above information would serve your purpose.

Thanking you,

Yours faithfully,  
For Gujarat Gas Co. Ltd.,

MK Manu  
Sr. Engineer (Vendor Development)